COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: G	ardner Denver						
	Model Number: L	55RS-75hp-145psi	Date:		01/04/21			
2	Air-cooled	X Water-cooled		Type:	Screw			
				# of Stages:	1			
3*	Full Load Operating P	Full Load Operating Pressure b		psig b				
4	Drive Motor Nominal	rive Motor Nominal Rating		hp				
5	Drive Motor Nominal	Drive Motor Nominal Efficiency		percent				
6	Fan Motor Nominal Ra	Fan Motor Nominal Rating (if applicable)		hp				
7	Fan Motor Nominal Ef	ficiency	70.0	percent				
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	67.00		318.6	21.03				
	56.77		271.4	20.92				
	47.26		224.2	21.08				
	38.33		177.0	21.66				
	29.93		129.8	23	3.06			
	21.91		82.6	26.53				
9*	Total Package Input Po	ower at Zero Flow c, d	4.5	kW				
10	Isentropic Efficiency		75.40		%			
11	35.00 – 30.00 – 30.00 – 25.00 – 25.00 – 20.00 – 15.00 – 10.00 –		150.0 200.0 Capacity (ACFM)	250.0 300	.0 350.0			
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity							

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS55-75F