COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

| MODEL DATA - FOR COMPRESSED AIR | | | | | | | | |
|---------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|--------------------------|----------------------------------------------|--|--|--|--|
| 1 | Manufacturer: Gardner De | nver | | | | | | |
| | Model Number: L290RS-340 | hp-190psi | Date | : 11/17/21 | | | | |
| 2 | Air-cooled X Water-cooled | | Туре | : Screw | | | | |
| | | | # of Stages | 1 | | | | |
| 3* | Full Load Operating Pressure b | | 190 | psig b | | | | |
| 4 | Drive Motor Nominal Rating | | 340 | hp | | | | |
| 5 | Drive Motor Nominal Efficiency | | 95.0 | percent | | | | |
| 6 | Fan Motor Nominal Rating (if ap | plicable) | 0.34 | hp | | | | |
| 7 | Fan Motor Nominal Efficiency | | 86.6 | percent | | | | |
| 8* | Input Power (kW) | | ty (acfm) ^{a,d} | Specific Power (kW/100 acfm) ^d | | | | |
| | 296.72 | | 201.0 | 24.71 | | | | |
| | 245.96 | | 002.5 | 24.53 | | | | |
| | 198.39 | | 303.3 | 24.70 | | | | |
| | 153.82 | | 603.1 | 25.50 | | | | |
| | 112.02 | | 102.1 | 27.86 | | | | |
| | 72.43 | | 99.7 | 36.27 | | | | |
| 9* | Total Package Input Power at Ze | | 20.2 | kW | | | | |
| 10 | Isentropic Efficiency | 7 | 74.28 | % | | | | |
| 11 | 40.00 35.00 25.00 20.00 15.00 20.00 20.00 400.0 600.0 800.0 1000.0 1200.0 1400.0 Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity | | | | | | | |

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

| Volume Flow Rate at specified conditions | | Volume Flow Rate | Specific Energy Consumption | Zero Flow Power |
|------------------------------------------|-----------------------|------------------|--------------------------------|--------------------|
| $\underline{m}^3 / \underline{min}$ | ft ³ / min | % | % | % |
| Below 0.5 | Below 17.6 | +/- 7 | +/- 8 | |
| 0.5 to 1.5 | 17.6 to 53 | +/- 6 | +/- 7 | +/- 10% |
| 1.5 to 15 | 53 to 529.7 | +/- 5 | +/- 6 | |
| Above 15 | Above 529.7 | +/- 4 | +/- 5 | |

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS160-290C