## **COMPRESSOR DATA SHEET**

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Gardner

## **Rotary Compressor: Fixed Speed MODEL DATA - FOR COMPRESSED AIR** Manufacturer: **Gardner Denver** ENV T250-125psi Model Number: 5/11/2021 Date: X Water-cooled Air-cooled Type: Screw Oil-injected X Oil-free 2 # of Stages:

		0	
3*	Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>	1525.6	acfm <sup>a,e</sup>
4	Full Load Operating Pressure <sup>b</sup>	125	psig <sup>b</sup>
5	Maximum Full Flow Operating Pressure <sup>c</sup>	125	psig <sup>c</sup>
6	Drive Motor Nominal Rating	335	hp
7	Drive Motor Nominal Efficiency	95.8	percent
8	Fan Motor Nominal Rating (if applicable)	4x 4.7	hp
9	Fan Motor Nominal Efficiency	86.5	percent
10*	Total Package Input Power at Zero Flow <sup>e</sup>	69.3	$kW^{e}$
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	311.30	$\mathbf{kW}^{\mathrm{d}}$
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	20.41	kW/100 cfm <sup>e</sup>

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

1

2

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute		me Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	$\underline{m^3 / \min}$	<u>ft<sup>3</sup> / min</u>	%	%	%
Member	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
ROT 030.2	Above 15	Above 529.7	+/- 4	+/- 5	
12/10 Day 2. This forms was deviated					



12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: ENVT165-315A