	COMPRESSOR DATA SHEET In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors					
			Rotary Compressor: Fixed Sp MODEL DATA - FOR COMPRES			
1	1 Manufacturer: Gardner Denver					
	Model	Model Number: STG2-125HP-175psi			7/21/2020	
2	Air-cooled X Water-cooled			Туре:	Screw	
				# of Stages:	1	
3*	Rated C	apacity at Full Lo	ad Operating Pressure ^{a, e}	475.0	acfm ^{a,e}	
4*		d Operating Press	h	175	psig ^b	
5	Maximu	m Full Flow Ope	rating Pressure ^c	175	psig ^c	
6		otor Nominal Rat		125	hp	
7	Drive M	otor Nominal Eff	iciency	95.4	percent	
8	Fan Mot	tor Nominal Ratin	g (if applicable)	NA	hp	
9	Fan Mot	tor Nominal Effic	iency	NA	percent	-
10*	Total Pa	ckage Input Powe	er at Zero Flow ^e	22.4	kW ^e	
11	Total Pa		er at Rated Capacity and Full Load	103.00	kW ^d	_
12*	Package Specific Power at Rated Capacity and Full Load Operating				kW/100 cfm ^e	
13	Isentrop	ic Efficiency		82.57	Percent	
	CAGI webs S: a. b.	ite for a list of partic Measured at the disch ISO 1217, Annex C; <i>a</i> The operating pressur for this data sheet. Maximum pressure att maximum pressure att	Performance Verification Program, these items are ipants in the third party verification program: arge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions e at which the Capacity (Item 3) and Electrical Consum tainable at full flow, usually the unload pressure setting ainable before capacity control begins. May require ad- ower at other than reported operating points will vary w	<u>www.cagi.org</u> lance with ption (Item 11) were measure for load/no load control or th ditional power.	ed	
Compressed Air & Gas Institu	е.	Tolerance is specified	in ISO 1217, Annex C, as shown in table below: ower" and "energy" are synonymous for purposes of this			
	nc	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member		<u>m³ / min</u>	<u>ft³ / min</u>	%	%	%
		Below 0.5	Below 17.6	+/- 7	+/- 8	
		0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
		1.5 to 15	53 to 529.7	+/- 5	+/- 6	

ROT 030.1

Above 15

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 4

+/- 5

Above 529.7