## **COMPRESSOR DATA SHEET**

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Gardner

## **Rotary Compressor: Fixed Speed MODEL DATA - FOR COMPRESSED AIR** Manufacturer: 1 **Gardner Denver** L290-340hp-100psi 1/4/2021 Model Number: Date: 2 Water-cooled Air-cooled Χ Type: Screw Х **Oil-injected** Oil-free # of Stages: 1 Rated Capacity at Full Load Operating Pressure a, e acfm<sup>a,e</sup> 3\* 1617.7 Full Load Operating Pressure <sup>b</sup> psig<sup>b</sup> 100 4 Maximum Full Flow Operating Pressure <sup>c</sup> psig<sup>c</sup> 5 110 Drive Motor Nominal Rating 6 340 hp Drive Motor Nominal Efficiency 7 **95.8** percent Fan Motor Nominal Rating (if applicable) 8 0.34 hp Fan Motor Nominal Efficiency 9 73.5 percent Total Package Input Power at Zero Flow<sup>e</sup> kW<sup>e</sup> 10\* 77.9

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

11

12\*

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.

287.44

17.77

- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

Total Package Input Power at Rated Capacity and

Specific Package Input Power at Rated Capacity

Full Load Operating Pressure<sup>d</sup>

and Full Load Operating Pressure

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

| Compressed Air & Gas Institute        | Volume Flow Rate<br>at specified conditions |                                      | Volume Flow Rate | Specific Energy<br>Consumption | No Load / Zero Flow<br>Power |
|---------------------------------------|---|--------------------------------------|------------------|--------------------------------|------------------------------|
|                                       | $\underline{m}^3 / \underline{min}$         | $\underline{ft}^3 / \underline{min}$ | %                | %                              | %                            |
| Member                                | Below 0.5                                   | Below 17.6                           | +/- 7            | +/- 8                          | +/- 10%                      |
|                                       | 0.5 to 1.5                                  | 17.6 to 53                           | +/- 6            | +/- 7                          |                              |
|                                       | 1.5 to 15                                   | 53 to 529.7                          | +/- 5            | +/- 6                          |                              |
| ROT 030.2                             | Above 15                                    | Above 529.7                          | +/- 4            | +/- 5                          |                              |
| 12/10 Deer 2. This form was developed |   |                                      |                  |                                |                              |



12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: L160-290C

kW<sup>d</sup>

 $kW/100 cfm^{e}$