## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Gardner Denver							
	Model Number: Ultima U132-145psi		Date:	05/11/21				
2	Air-cooled X Water-cooled	r-cooled X Water-cooled		Screw				
	Lubricated X Oil Free		# of Stages:	2				
3*	Full Load Operating Pressure <sup>b</sup>	100	100 psig <sup>b</sup>					
4	Drive Motor Nominal Rating	89	<b>89</b> hp					
5	Drive Motor Nominal Efficiency	97.0	97.0 percent					
6	Fan Motor Nominal Rating (if applicable)	0.78	<b>0.78</b> hp					
7	Fan Motor Nominal Efficiency	87.9	percent					
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>					
	143.91	817.7	17.60					
ο*	122.14	701.5	17.41					
8*	102.04	585.3	17.43					
	83.47	469.1	17.80					
	66.32	352.8	18.79					
	50.52	236.6	21.35					
9*	Total Package Input Power at Zero Flow c, d	8.0	8.0 kW					
10	35.00							
	Specific Power (kW/100 ACEM) 20.00							
	15.00			_				
	10.00 100.0 200.0	300.0 400.0 500.0 60  Capacity (ACFM)	00.0 700.0 80	900.0				
	Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity							

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: U75-160B