COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacturer: C	ardner Denver			
	Model Number: I	29RS-40hp-190psi		Date:	01/04/21
2	X Air-cooled Water-cooled			Type:	Screw
			#	of Stages:	1
3*	Full Load Operating P	b ressure	190	psig ^b	
4		rive Motor Nominal Rating		hp	
5	Drive Motor Nominal	Drive Motor Nominal Efficiency		percen	
6	Fan Motor Nominal Rating (if applicable)		1.15	hp	
7	Fan Motor Nominal E	ficiency	82.5	percent	
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	36.47		134.9	27.0	
Ovik	31.60		114.4	27.62	
8*	27.14		93.9	28.90	
	23.06		73.4	31.42	
	19.36		52.9	36.60	
	15.95		32.4	49.2	23
9*	Total Package Input P	ower at Zero Flow ^{c, d}	4.5		kW
10	Isentropic Efficiency		62.48		%
	50.00				
	45.00 -				
	40.00 -				
	ני ב 35.00 -		<u></u>		
	- 0.00 - 400				
11	(W100 4 CEW) 35.00 - 30.00 - 30.00 - 25.00 -				
11	20.00				
	15.00 -				
	10.00 -				
	0.	20.0 40.0	60.0 80.0 100.0	120.0 140.	.0 160.0

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

ROT 031.1

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
n	m^3 / min	$\underline{ft^3 / min}$	%	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8		
0).5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
А	Above 15	Above 529.7	+/- 4	+/- 5		

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS23-29E