COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MOD	EL D	ATA - I	OR CO	OMPRI	ESSED A	AIR		
1	Manufacturer:	Gardn	er Denv	ver						
	Model Number: VST110-74hp(2S)-125ps				psi	si Dat			:	01/04/21
2	Air-cooled X Water-cooled						Type	:	Screw	
							#	of Stages	:	2
3*	Full Load Operation	Full Load Operating Pressure b				125		psig		
4	Drive Motor No	Orive Motor Nominal Rating				2 x 74		hp		
5	Drive Motor Nominal Efficiency				94.0		percent			
6	Fan Motor Non	Fan Motor Nominal Rating (if applicable)				NA		hp		
7	Fan Motor Non	ninal Efficien	су			NA			percent	
	Input Power			Capa	acity (acf	m) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	128.90					751.0		17.16		
0.46	115.98					675.9		17.16		
8*	103.88					600.8		17.29		
	92.36					525.7		17.57		
	81.16					450.6		18.01		
	56.90		1		289.0		19.69			
9*	Total Package Input Power at Zero Flow c, d					0.0		kW		
10	Isentropic Effic	Isentropic Efficiency				83.86				%
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0.0	100.0	200.0	300.0 Capacity (500.0	600.0	700.0	800.0

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B