## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer: Gardner Denver								
	Model Number: VST180-120hp(2S)-100psi			Date:	01/04/21				
2	X Air-cooled W	X Air-cooled Water-cooled		Type:	Screw				
	X Lubricated Oil Free			# of Stages:	2				
3*	Full Load Operating Pressure b	ng Pressure b		psig b					
4	Drive Motor Nominal Rating		2 x 120	hp					
5	Drive Motor Nominal Efficiency		94.0	percent					
6	Fan Motor Nominal Rating (if applicable)		10	hp					
7	Fan Motor Nominal Efficiency	Notor Nominal Efficiency		percent					
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>					
	240.86		1382.0	17.43					
	200.44		1174.7	17.06					
	157.09		967.4	16.24					
	118.79		760.1	15.63					
	87.62		552.8	15.85					
	54.00		305.0	17.70					
9*	Total Package Input Power at Zero Flow c, d		0.0	kW					
10	35.00  30.00  30.00  15.00  10.00  20.00  400.0  600.0  800.0  10								

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B