47728697001 rev A



COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	MODEL DATA -	FOR COMPRESSED	AIR			
1	Manufacturer: Gardner Denver					
	Model Number TVS74		Date:	e: 07/12/21		
2	X Air-cooled Water-cooled		Туре:		Screw	
	Lubricated X Oil-Free		# of Stages:	2		
3*	Full Load Operating Pressure ^b	150		$psig^b$		
4	Drive Motor Nominal Rating	100		hp		
5	Drive Motor Nominal Efficiency	95.2		percent		
6	Fan Motor Nominal Rating (if applicable)	5.4		hp		
7	Fan Motor Nominal Efficiency	88.6		percent		
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d			
	92.4	368	25.11			
Ī	87.1	345	25.25			
8*	81.0	319	319 25.40			
	75.0	293 25.62		62		
	69.3	267	25.98			
	63.9	241	26.5	56		
9*	Total Package Input Power at Zero Flow ^{c, C}	0.0		kW		
	35.00 (KW)100 ACFM) 30.00					
10	15.00	50 200 250 300 Capacity (ACFM)	350 400	450 500		
	0 50 100 1 Note: Graph is only Note: Y-Axis Scale, 10 to		Section 8	450 500		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m ³ /min	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.