COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

1	Manufacturer:	Gardner Denver			
	Model Number: VST260-175hp(2S)-125psi			Date:	01/04/21
2	Air-coole	d X Water-cooled		Type:	Screw
	X Lubricate			# of Stages:	2
3*	Full Load Operation	ng Pressure ^b	125	psig	
4	Drive Motor Nominal Rating		2 x 175	hp	
5	Drive Motor Nominal Efficiency		94.0	percen	
6	Fan Motor Nominal Rating (if applicable)		NA	hp	
7	Fan Motor Nomin	al Efficiency	NA	percen	
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	325.70		1885.0	17.28	
	270.59		1602.3	16.89	
8*	224.44		1319.5	17.01	
	180.40		1036.8	17.40	
	135.14		754.0	17.92	
	73.30		377.0	19.44	
9*	Total Package Inp	ut Power at Zero Flow c, d	0.0	kW	
10	Specific Power (kW/100 ACFM)	55.00			
	1	0.00 + 0.0 200.0 400.0 600	.0 800.0 1000.0 1200.0	1400.0 1600.0 1	800.0 2000.0
		0.0 200.0 400.0 600	Capacity (ACFM)		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST225-260B