COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Gardner Denver						
	Model Number: VST110-74hp(2S)-100psi			Date	: 01/04/21			
2	X Air-coole	ed Water-coole	d	Туре	Screw			
				# of Stages	2			
3*	Full Load Operati	ng Pressure b	100		psig b			
4	Drive Motor Nominal Rating		2 x 7	'4	hp			
5	Drive Motor Nominal Efficiency		94.0)	percent			
6	Fan Motor Nominal Rating (if applicable)		2) 10		hp			
7	Fan Motor Nominal Efficiency		89.5	5	percent Specific Power			
	Input Power (kW)		Capacity (a	ncfm) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	128.50		816.	0	15.75			
8*	114.70		734.	4	15.62			
8*	102.07		652.	8	15.64			
	90.34		571.	2	15.82			
	79.17		489.	6	16.17			
	51.60		c, d	<u> </u>	17.85			
9*	Total Package Input Power at Zero Flow		0.0		kW			
10	Isentropic Efficie	ncy	82.1	0	<u>%</u>			
	3	5.00						
	3	0.00						
11	Specific Power (kW/100 ACFM)	5.00						
	Specifi (kW/10	20.00						
		15.00						
		0.00 100.0 200.0		500.0 600.0 700.0	800.0 900.0			
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity							

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B