## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

## **Rotary Compressor: Variable Frequency Drive**

1	Manufacturer: Gardner De	nver			
	Model Number: ENV TVS25	50 -125psi	Date:	05/11/21	
2	X Air-cooled Water	r-cooled	Туре:	ype: Screw	
	Lubricated X Oil Fr	ree	# of Stages:	2	
3*	Full Load Operating Pressure <sup>b</sup>	125		psig <sup>b</sup>	
4	Drive Motor Nominal Rating	335		hp	
5	Drive Motor Nominal Efficiency	96.2	percent		
6	Fan Motor Nominal Rating (if app	licable) <b>4X 6.7</b>		hp	
7	Fan Motor Nominal Efficiency	86.5		percent	
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>		Specific Power (kW/100 acfm) <sup>d</sup>	
	324.60	1536.2	21.1		
	284.70	1373.7	20.7	72	
8*	246.00	1190.1	20.0	20.67	
	209.10	995.9	21.0	21.00	
	174.00	801.6	21.7	21.71	
	140.70	614.5	22.9	22.90	
9*	Total Package Input Power at Zero	• Flow <sup>c, d</sup> 26.2		kW	
10	35.00				
	30.00				
	25.00 (WM)100 ACFM) Specific Power Society Specific Power				
	20.00 (KM/10				
	15.00				

Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator

Consult CAGI website for a list of participants in the third party verification program:

CAGI Compressed Air & Gas Institute

Member

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

		me Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
	$\underline{m^3 / \min}$	<u>ft<sup>3</sup> / min</u>	%	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8		
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
ROT 031.2	Above 15	Above 529.7	+/- 4	+/- 5		

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: ENVTVS200-315A

www.cagi.org