COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
2	Model Number: Ultima U132-145psi		Date:	05/11/21			
	Air-cooled X Water-cooled		Type:	Screw			
	Lubricated X Oil Free		# of Stages:	2			
3*	Full Load Operating Pressure b	145 psig ^b					
4	Drive Motor Nominal Rating	89 hp					
5	Drive Motor Nominal Efficiency	97.0 percent					
6	Fan Motor Nominal Rating (if applicable)	0.78	hp				
7	Fan Motor Nominal Efficiency	87.9	percent				
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
8*	146.58	701.4	20.90				
	129.69	615.5	21.07				
	113.76	529.6	21.48				
	98.72	443.7	22.25				
	84.51	357.8	23.62				
	71.18 c, d	271.9	26.18				
9*	Total Package Input Power at Zero Flow	8.0	kW				
10		Capacity (ACFM) Graph is only a visual representation of the data in Section 8					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: U75-160B