COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Gardner De	enver						
	Model Number: VST75-50hp(2S)-125psi			Date:	01/04/21			
2	X Air-cooled Water-cooled			Type:	Screw			
				# of Stages:	2			
3*	Full Load Operating Pressure b		125	psig b				
4	Drive Motor Nominal Rating		2 x 50	hp				
5	Drive Motor Nominal Efficiency		94.0		percent			
6	Fan Motor Nominal Rating (if applicable)		5		hp			
7	Fan Motor Nominal Efficiency		85.5	percent				
8*	Input Power (kW)		pacity (acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d			
	91.91		513.0	17.92				
	77.50		436.1	17.77				
	64.25		359.1	17.89				
	52.31		282.2	18.54				
	41.04		205.2	20.00				
	27.40		119.0	23.03				
9*	Total Package Input Power at Zer	o Flow c, d	0.0		kW			
10	Isentropic Efficiency		81.71		%			
11	35.00 30.00 25.00 25.00 15.00 10.00 10.00	00.0 200.0	300.0	200.0 500.	0 600.0			
		Capacity						
	Note: Y-A	Graph is only a visual repr axis Scale, 10 to 35, + 5kW/10 X-Axis Scale, 0 to 25%	esentation of the data in Oacfm increments if neces over maximum capacity	Section 8 essary above 35				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B