-	1	Monuf		MODEL DATA - FOR COMPRES	SED AIK		-
-	1	Manui	lacturer:	acturer: Gardner Denver			_
		Model	Number:	STG2-150HP-200psi	Date:	7/21/2020	-
	2	X	Air-cooled	Water-cooled	Type:	Screw	
					# of Stages:	1	
	3*	Rated C	Capacity at Full Lo	ad Operating Pressure <sup>a, e</sup>	552.0	acfm <sup>a,e</sup>	
	4*	Full Loa	d Operating Pressure <sup>b</sup>		200	psig <sup>b</sup>	1
	5	Maximu	um Full Flow Oper	cating Pressure <sup>c</sup>	200	psig <sup>c</sup>	
	6	Drive M	Iotor Nominal Rat	ing	150 95.8	hp	
	7	Drive M	Iotor Nominal Eff	ciency			
	8	Fan Mo	tor Nominal Rating (if applicable) tor Nominal Efficiency		5 85.5	hp	
	9	Fan Mo					
	10*	Total Pa	ackage Input Powe	er at Zero Flow <sup>e</sup>	29.1	kW <sup>e</sup> kW <sup>d</sup>	
	11		ackage Input Powe ng Pressure <sup>d</sup>	r at Rated Capacity and Full Load	132.50		
	12*	Package Pressure	-	t Rated Capacity and Full Load Operating	24.00	kW/100 cfm <sup>e</sup>	
	13	Isentrop	oic Efficiency		79.76	Percent	
		CAGI webs : a. b. c. d.	site for a list of partic: Measured at the disch ISO 1217, Annex C; <i>A</i> The operating pressure for this data sheet. Maximum pressure att maximum pressure att Total package input p	Performance Verification Program, these items are ipants in the third party verification program: arge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions e at which the Capacity (Item 3) and Electrical Consum ainable at full flow, usually the unload pressure setting ainable before capacity control begins. May require ad wer at other than reported operating points will vary w in ISO 1217, Annex C, as shown in table below:	www.cagi.org dance with ption (Item 11) were measur for load/no load control or th ditional power.	ed	-
Compressed Air	ir & Gas Institute		NOTE: The terms "po	ower" and "energy" are synonymous for purposes of this Volume Flow Rate	s document.	Specific Energy	No Load / Zero Flow
				at specified conditions	Volume Flow Rate	Consumption	Power
Mem	Member		m <sup>3</sup> / min	$\underline{\text{ft}^3} / \underline{\text{min}}$	%	%	%

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 7

+/- 6

+/- 5

+/- 4

+/- 8

+/- 7

+/- 6

+/- 5

+/- 10%

Below 17.6

17.6 to 53

53 to 529.7

Above 529.7

Below 0.5

0.5 to 1.5

1.5 to 15

Above 15