COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacturer:	Gardne	er Denver						
	Model Number: L30RS-40hp-145psi					Date	:	01/04/21	
2	X Air-cooled Water-cooled					Туре	:	Screw	
						# of Stages	:	1	
3*	Full Load Operating	Load Operating Pressure ^b					psig		
4	Drive Motor Nomin	rive Motor Nominal Rating			40		hp		
5	Drive Motor Nominal Efficiency				94.5		percen		
6	Fan Motor Nominal Rating (if applicable)				1.2		hp		
7	Fan Motor Nomina	l Efficiend	cy		82.5		percen		
	Input Power (kW)			Capac	ty (acfm) ^a	,d	Specific Power (kW/100 acfm) ^d		
F	36.99				170.0		21.76		
F	32.64				150.4		21.70		
8*	28.73				130.8		21.96		
	25.23				111.2		22.69		
	21.94				91.6		23.95		
	18.98			-	72.0		26.36		
9*	Total Package Input Power at Zero Flow ^{c, d}			1	4.8		kW		
10	Isentropic Efficiency				70.05		%		
	35.	00							
	30.	00							
	25.00 Specific Fower 20.00 Specific Power 20.00								
11									
	15.	00							
	10	00							

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

ROT 031.1

	-	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
Γ	$\underline{m}^3 / \underline{min}$	$\underline{\text{ft}^3} / \min$	%	%	%	
Γ	Below 0.5	Below 17.6	+/- 7	+/- 8		
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
	Above 15	Above 529.7	+/- 4	+/- 5		

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS30-45E