COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MOI	DEL DATA - F	OR COMPRESSEI	O AIR		
1	Manufacturer:	Gardı	ner Denver				
	Model Number: VST110-74hp(2S)-100ps Air-cooled X Water-cooled			si Date:		01/04/2	
2					Type:	Screw	
					# of Stages:	2	
3*	Full Load Operating Pressure b			100	<u> </u>	psig b	
4	Drive Motor No	Drive Motor Nominal Rating			hp		
5	Drive Motor No	Drive Motor Nominal Efficiency			percent		
6	Fan Motor Non	Fan Motor Nominal Rating (if applicable)		NA	hp		
7	Fan Motor Non	ninal Efficie	ncy	NA	percen Specific Power		
	Input Power (kW)			Capacity (acfm) ^{a,d}	(kW/100 acfm) ^d		
	127.60			816.0	15.64		
8*	114.10			734.4	1	5.54	
8.	101.66			652.8	1	5.57	
	90.04			571.2	1	5.76	
	78.93			489.6	1	6.12	
	51.40		c, d	289.0	1	7.79	
9*	Total Package Input Power at Zero Flow			0.0	kW		
10	Isentropic Efficiency			82.52		%	
11		35.00					
	30.00						
	Power ACFM)	25.00					
	Specific Power (kW/100 ACFM)	20.00					
		15.00					
		10.00	1 1	1			
		0.0	100.0 200.0 3		00.0 700.0	800.0 900.0	
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity						

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B