COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

			DEL D	ATA - F		OMPRI	ESSED A	AIR		
1	Manufacturer:	Gardn	ner Den	ver						
	Model Number: VST90-60hp(2S)-100psi							Date): 	01/04/21
2	X Air-cooled Water-cooled						Туре):	Screw	
							# (of Stages	3:	2
3*	Full Load Opera	Full Load Operating Pressure b				100		psig ^b		
4	Drive Motor No	Orive Motor Nominal Rating				2 x 60		hp		
5	Drive Motor No	Drive Motor Nominal Efficiency				94.0		percent		
6	Fan Motor Nom	Fan Motor Nominal Rating (if applicable)				5		hp		
7	Fan Motor Nom	Motor Nominal Efficiency				85.5		percent Specific Power		
8*	Input Power			Capa	acity (acf	m) ^{a,d}		Power acfm) d		
	116.84					677.0		17.26		
	95.67					575.5		16.63		
	77.78					473.9		16.41		
	62.06					372.4		16.67		
	47.44					270.8			17.52	
	24.80				115.0		21.57			
9*	Total Package I	Total Package Input Power at Zero Flow c, d				0.0		kW		
10	Isentropic Effic	Isentropic Efficiency				78.70				%
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0.0	100.0 Note: G	200.0	300.0 Capacity (visual repre		500.0	600.0 tion 8	700.0	800.0

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B