	COMPRESSOR DATA SHEET					
	In Accor	rdance with Fee	leral Uniform Test Method for Cert		r Compressors	Denver
			Rotary Compressor: Fixed Sp			
MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Gardner Denver					
	Mode	el Number:	L90(F)-130#	Date:	12/17/2021	
2		Air-cooled	X Water-cooled	Type:	Screw	
				# of Stages:	1	
3*	Rated C	apacity at Full Loa	ad Operating Pressure ^{a, e}	577.2	acfm ^{a,e}	
4*		ad Operating Press		125	psig ^b	
5	Maximu	ım Full Flow Oper	rating Pressure ^c	137	psig ^c	
6	Drive M	Iotor Nominal Rati	ing	125	hp	
7	Drive M	lotor Nominal Effi	ciency	95	percent	
8	8 Fan Motor Nominal Rating (if applicable)			0.9	hp	
9	Fan Mo	tor Nominal Effici	ency	72	percent	
10*		ackage Input Powe		27.1	kW ^e	
11		ackage Input Powe ng Pressure ^d	r at Rated Capacity and Full Load	106.18	kW^d	
12*			Rated Capacity and Full Load Operating	18.40	kW/100 cfm ^e	
13	Isentrop	ic Efficiency		81.65	Percent	
	lt CAGI webs ES: a. b. c. d.	site for a list of partic Measured at the disch ISO 1217, Annex C; J The operating pressur for this data sheet. Maximum pressure att maximum pressure att Total package input p Tolerance is specified	Performance Verification Program, these items are ipants in the third party verification program: arge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions e at which the Capacity (Item 3) and Electrical Consum tainable at full flow, usually the unload pressure setting ainable before capacity control begins. May require ad ower at other than reported operating points will vary w in ISO 1217, Annex C, as shown in table below:	<u>www.cagi.org</u> lance with ption (Item 11) were measure for load/no load control or the ditional power. ith control strategy.	ed	
Compressed Air & Gas Instit	tute	NOTE: The terms "po	ower" and "energy" are synonymous for purposes of this Volume Flow Rate		Specific Energy	No Load / Zero Flow
Member		$\underline{m}^3 / \underline{min}$	at specified conditions $\frac{ft^3 / min}{ft^3}$	Volume Flow Rate %	Consumption %	Power %
ivieliloei		Below 0.5	Below 17.6	+/- 7	+/- 8	/0
		0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
		1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%

ROT 030.1

12/19 Rev 2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data. Configurator: L90-132F

Above 529.7

+/- 4

+/- 5

Above 15