## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Gardr	ner Denver						
2	Model Number: Ultima U160-145psi			Date:	05/11/21			
	X Air-cooled Water-cooled			Type:	Screw			
	Lubricated X Oil Free			# of Stages:	2			
3*	Full Load Operating Pressure <sup>b</sup>		145	psig				
4	Drive Motor Nominal Rating		107	hp				
5	Drive Motor Nominal Efficiency		97.0	percent				
6	Fan Motor Nominal Rating (if applicable)		0.78, 2X 3.75	hp				
7	Fan Motor Nominal Efficier	icy	87.9	percent				
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	180.48		835.0	21.61				
Oute	156.62		722.3	21.68				
8*	132.13		609.7	21.67				
	110.22		497.1	22.17				
	90.43		384.5	23.52				
	72.11		271.9	26.52				
9*	Total Package Input Power at Zero Flow c, d		8.4	kW				
10	35.00 30.00 25.00 25.00 15.00 10.00 0.0	35.00 30.00 25.00 20.00 15.00						

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: U75-160B