## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Gardne	er Denver						
	Model Number: L23RS		Date:	02/11/21				
2	X Air-cooled		Type:	Screw				
				# of Stages:	1			
3*	Full Load Operating Pressure b		125		psig			
4	Drive Motor Nominal Rating		30		hp			
5	Drive Motor Nominal Efficiency		91.7		percent			
6	Fan Motor Nominal Rating (if applicable)		1.15		hp			
7	Fan Motor Nominal Efficien	Motor Nominal Efficiency			percent			
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>		Specific Power (kW/100 acfm) <sup>d</sup>			
	29.04		135.0		21.51			
0*	25.05		115.6	2	1.67			
8*	21.36		96.2	2	22.20			
	17.92		76.7	2	3.36			
	14.69		57.3	2	25.64			
	11.63		37.9	3	30.69			
9*	Total Package Input Power at Zero Flow c, d		4.3 65.49		kW			
10	Isentropic Efficiency	Isentropic Efficiency			%			
11	35.00 30.00 30.00 25.00 20.00 10.00 0.0 20.0			in Section 8	140.0 160.0			
	Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity							

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}^3} / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: I RS23-291