## **COMPRESSOR DATA SHEET**



## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Displacement** 

	T		FOR COMPRESSEI	) AIR		
1	Manufacturer:	Gardner Denver				
	Model Number:	SAV-300hp-EAU-125p	osi	Date:	01/04/21	
2	X Air-cooled Water-cooled			Type:	Screw	
	X Lubrica	nted Oil Free		# of Stages:	1	
3*	Full Load Opera	ting Pressure b	125	b psig		
4	Drive Motor Nominal Rating		300	hp		
5	Drive Motor Nominal Efficiency		95.8	percent		
6	Fan Motor Nominal Rating (if applicable)		10	hp		
7	Fan Motor Nom	inal Efficiency	88.5	percent		
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	258.6		1206	21.44		
	240.2		1085	22.14		
	208.0		844	24.64		
	181.3		603	30.07		
	173.4		482	35.98		
9*	Total Package Input Power at Zero Flow c, d		49.8	kW		
10	Isentropic Efficiency at Full Flow Rated Capacity and Full Load Operating Pressure		70.1	%		
11	Specific Power (kW/100 ACFM)	40.00 35.00 25.00 20.00 15.00 10.00 0 200 400  Note: Graph is only a	600 800  Capacity (ACFM)  visual representation of the data in S	1000 1200 Section 8	1400	
	Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity					

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	folume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	, , , , ,
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 032.1

6/20. Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: EAU99AA