COMPRESSOR DATA SHEET



In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

	Manufacture	r: Gar	dner Denver			
	Model Number: SAV-150hp-EAQ-125ps			osi	Date:	06/26/20
2	X Air-cooled Water-cooled				Type:	Screw
	X Lubricated Oil Free			# of Stages:	1	
k	Full Load Operating Pressure ^b		125		psig ^b	
	Drive Motor Nominal Rating			150	hp	
	Drive Motor Nominal Efficiency			95.8	percent	
	Fan Motor Nominal Rating (if applicable)			3	hp	
	Fan Motor N	Fan Motor Nominal Efficiency 89.5		<u> </u>	percent Specific Power	
8*	Input Power (kW)			Capacity (acfm) ^{a,d}	(kW/100 acfm) ^d	
	126.0		608	20.72		
	117.4		547	21.46		
	101.4			426	23.83	
	88.2			304	29.01	
	84.2		243	34.64		
ĸ	Total Package Input Power at Zero Flow c, d			24.7		kW
)	Isentropic Efficiency at Full Flow Rated Capacity and Full Load Operating Pressure			72.5		%
11	35.00 30.00 25.00 20.00 20.00		· · · · · · · · · · · · · · · · · · ·			
	Spe	20.00				
	15.00					
		10.00	100 200	300 400	500 600	700
				Capacity (ACFM)		
			Note: Y-Axis Scale, 10 to 35	visual representation of the data in t , + 5kW/100acfm increments if necess e, 0 to 25% over maximum capacity		
node	els that are tested in	the CAGI Per	formance Verification	Program, these items are ver	rified by the third p	arty administrator

Compressed Air & Gas Institute

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member Volume Flow Rate at specified conditions Specific Energy Zero Flow Consumption Volume Flow Rate Power m^3 / min ft³ / min % % % Below Below 17.6 +/- 7 +/- 8 0.5 0.5 to 1.5 17.6 to 53 +/- 6 +/- 7 +/- 10% 1.5 to 15 53 to 529.7 +/- 5 +/- 6 Above 15 Above 529.7 +/- 4 +/- 5 ROT 032.1

6/20. Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.