COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR 1 Manufacturer: Gardner Denver Model Number: ENV T315-420hp-145psi Date: 6/26/2020 2 Air-cooled Water-cooled Type: Screw Oil-injected X Oil-free # of Stages: 2 Rated Capacity at Full Load Operating Pressure a, e acfm^{a,e} 3* 1585.0 Full Load Operating Pressure b psigb 145 4 Maximum Full Flow Operating Pressure c <u>psig</u>^c 5 145 **Drive Motor Nominal Rating** 420 6 hp **Drive Motor Nominal Efficiency** 7 95.4 percent Fan Motor Nominal Rating (if applicable) 8 2 hp Fan Motor Nominal Efficiency 9 86.5 percent Total Package Input Power at Zero Flow^e kW^{e} 10* **73** Total Package Input Power at Rated Capacity and $kW^{d} \\$ 338.30 11 Full Load Operating Pressure^d Specific Package Input Power at Rated Capacity 12* 21.34 kW/100 cfm^e and Full Load Operating Pressure

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	



Member

ROT 030.2

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org