## COMPRESSOR DATA SHEET



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MO	DEL DATA - FO	OR COMPRESSE	D AIR		
1	Manufacturer:	Gard	ner Denver				
	Model Number: L11RS-15hp-125psi				Date:	07/09/20	
2	X Air-cooled Water-cooled				Type:	Screw	
					# of Stages:	1	
3*	Full Load Operating Pressure b			130		psig b	
4	Drive Motor Nominal Rating			15	hp		
5	Drive Motor Nominal Efficiency			91.0	percent		
6	Fan Motor Nominal Rating (if applicable)			NA	hp		
7	Fan Motor Nor	ninal Effici	ency	NA	percent Specific Power		
8*	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>		(kW/100 acfm) <sup>d</sup>	
	14.08			56.9		24.74	
	12.60			51.2		24.60	
8*	11.22			45.5	:	24.63	
	9.93			39.8	:	24.92	
	8.73			34.1	25.57		
	6.50			21.6	;	30.09	
9*	Total Package Input Power at Zero Flow c, d			4.0	kW		
10	Isentropic Efficiency			59.52		%	
11	Specific Power (RW/100 ACFM)	35.00 30.00 25.00 20.00 15.00	10.0 20.0	0 30.0	, , , , , , , , , , , , , , , , , , ,	0 60.0	
		1	Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35, 4	Capacity (ACFM)  sual representation of the data in  + 5kW/100acfm increments if nece 0 to 25% over maximum capacity			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \min$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data