COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	Gard	ner Denver						
	Model Number: L23RS-30hp-190psi				Date:	01/04/21			
2	X Air-cooled Water-cooled				Type:	Screw			
					# of Stages:	1			
3*	Full Load Operating Pressure ^b			190		psig			
4	Drive Motor Nominal Rating			30		hp			
5	Drive Motor Nominal Efficiency			91.7		percent			
6	Fan Motor Nominal Rating (if applicable)			1.15		hp			
7	Fan Motor Nominal Efficiency			82.5		percent Specific Power			
	Input Power (kW)			Capacity (acfm) ^{a,c}	l I	kW/100 acfm) ^d			
	28.83			102.1		28.24			
8*	26.41			91.2		28.96			
8*	24.15			80.3		30.07			
	22.02			69.4		31.73			
	20.02			58.6		34.16			
	18.12		c, d	47.7		37.99			
9*	Total Package Input Power at Zero Flow			4.3 57.49		kW			
10	Isentropic Effic	Isentropic Efficiency				<u>%</u>			
		40.00							
		35.00							
	wer FM)	30.00							
11	fic Pov	25.00							
	Specific Power (kW/100 ACFM)	20.00							
		15.00							
		10.00	20.0 40	0.0 60.0	80.0	00.0 120.0			
		0.0	20.0 40	Capacity (ACFM)	00.0 IC	120.0			
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity								

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

1	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS23-29E