COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
	Model Number: VST150-100hp(2S)-100psi		Date:	01/04/21			
2	Air-cooled X Water-cool	led	Type:	Screw			
		#	of Stages:	2			
3*	Full Load Operating Pressure b	g Pressure ^b 100		psig b			
4	Drive Motor Nominal Rating	Iotor Nominal Rating 2 x 100		hp			
5	Drive Motor Nominal Efficiency	NA	percent				
6	Fan Motor Nominal Rating (if applicab	ole) NA	hp				
7	Fan Motor Nominal Efficiency	NA	percent				
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	171.93	1050.0	16.37				
	140.98	892.5	15.80				
	114.11	735.0	15.53				
	90.57	577.5	15.68				
	69.17	420.0	16.47				
	52.00	289.0	17.9	9			
9*	Total Package Input Power at Zero Flor	w 0.0	kW				
10	Isentropic Efficiency	ic Efficiency 83.27		%			
11	35.00 30.00 25.00 25.00 15.00 10.00 200.0	400.0 600.0 800. Capacity (ACFM)		1200.0			
	Note: Y-Axis Scale	is only a visual representation of the data in Se e, 10 to 35, + 5kW/100acfm increments if necessa Axis Scale, 0 to 25% over maximum capacity					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B