## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

								ED AIR			
1	Manufacturer:	Gard	ner Der	nver							
	Model Number: L15RS-20hp-130psi							Dat	e:	01/04/21	
2	X Air-cooled Water-cooled							Тур	e:	Screw	
								# of Stage	s:	1	
3*	Full Load Oper	Full Load Operating Pressure b					25		psig b		
4	Drive Motor No	Prive Motor Nominal Rating					20		hp		
5	Drive Motor No	Drive Motor Nominal Efficiency					1.0		percent		
6	Fan Motor Non	Fan Motor Nominal Rating (if applicable)				N	JA		hp		
7	Fan Motor Non	n Motor Nominal Efficiency				N	<b>JA</b>		percent		
8*	Input Powe			(	Capacity	(acfm) <sup>a,o</sup>	ı l	Specific Power (kW/100 acfm) <sup>d</sup>			
	18.50					8.	1.4		22.73		
	16.97				74.7			22.72			
	14.78				6.	3.9		23.12			
	12.71					5.	3.2		23.91		
	10.76				42	2.4		25.38			
	8.92			ı d	3	1.6		28.20			
9*	Total Package Input Power at Zero Flow c, d						2.1		kW		
10	Isentropic Effic	Isentropic Efficiency				61	.86			%	
11	Specific Power (kW/100 ACFM)	_	40.0 acity (ACFN		60.0 70.0	80.0	90.0				
	Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity										

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

1	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS15-22C