COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Displacement

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Gardner Denver						
	Model Number:	SAV-300hp-EAU-100p	si	Date:	01/04/21			
2	X Air-cool	ed Water-cooled		Type:	Screw			
	X Lubricat	ted Oil Free		# of Stages:	1			
3*	Full Load Operat	ring Pressure b	100	b psig				
4	Drive Motor Nominal Rating		300		hp			
5	Drive Motor Nor	ninal Efficiency	95.8	percent				
6	Fan Motor Nominal Rating (if applicable)		10	hp				
7	Fan Motor Nomi	nal Efficiency	88.5		percent			
8*	Input Power	(kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	278.9		1481	18.83				
	259.0		1333	19.43				
	224.2		1037		21.62			
	195.2		741		26.34			
	186.7		592	31.54				
9*	Total Package In	put Power at Zero Flow c, d	58.5	kW				
10	Specific Power (kW/100 ACFM)	Note: Y-Axis Scale, 10 to 35	600 800 1000 Capacity (ACFM) visual representation of the data in 5, + 5kW/100acfm increments if necese, 0 to 25% over maximum capacity	1200 Section 8 ssary above 35	1400 1600			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	., 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 032.2

6/20 Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: EAU99AA