## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Variable Frequency Drive**

1	Manufacturer: Ga	rdner Denver			
	Model Number: L2	6RS-35hp-190psi		Date:	01/04/21
2	X Air-cooled	Water-cooled		Type:	Screw
			# 0	of Stages:	1
3*	Full Load Operating Pre	Ill Load Operating Pressure <sup>b</sup> 190		psig <sup>b</sup>	
4	Drive Motor Nominal Rating		35	hp	
5	Drive Motor Nominal Efficiency		91.7	percent	
6	Fan Motor Nominal Rating (if applicable)		1.15	hp	
7	Fan Motor Nominal Eff	ciency	82.5	percent	
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>	
	33.94		125.7	27.00	
	29.52		107.1	27.56	
8*	25.54		88.4	28.89	
	21.97		69.8	31.48	
	18.77		51.1	36.73	
	15.82		32.5	48.6	8
9*	Total Package Input Po	wer at Zero Flow <sup>c, d</sup>	4.4		kW
10	Isentropic Efficiency		62.14		%
	50.00				
	45.00				
	40.00				
			$\backslash$		
	ACF				
	00.00 x/100 v/100				-
11					
	20.00				
	15.00				
		20.0 40.0	60.0 80.0	100.0 120.0	140.0

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

ROT 031.1

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
n	$m^3 / min$	$\underline{ft^3 / min}$	%	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8		
0	).5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
А	Above 15	Above 529.7	+/- 4	+/- 5		

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS23-29E