## **COMPRESSOR DATA SHEET**



## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Displacement** 

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Den	ver					
	Model Number: SAVG2-125h	p-100psi	Date	01/04/21			
2	X Air-cooled Water-	cooled	Type	Screw			
	X Lubricated Oil Fre	e	# of Stages:	1			
3*	Full Load Operating Pressure b		100	psig			
4	Drive Motor Nominal Rating		125	hp			
5	Drive Motor Nominal Efficiency	9	95.4	percent			
6	Fan Motor Nominal Rating (if appli	Nominal Rating (if applicable)		hp			
7	Fan Motor Nominal Efficiency		85.5				
8*	Input Power (kW)	Capacit	y (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
	115.0		650	17.69			
	95.2		522	18.23			
	82.7		419	19.76			
	74.3		325	22.87			
	72.7		259	28.10			
9*	Total Package Input Power at Zero I		33.1	kW			
10	Isentropic Efficiency at Full Flow R Capacity and Full Load Operating P		75.1	%			
11	35.00 30.00 25.00 25.00 15.00			600 700			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	<u>ft<sup>3</sup> / min</u>	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	.,
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 032.1

6/20. Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: SAV125-150G2A