	COMPRESSOR DATA SHEET In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors					
			Rotary Compressor: Fixed Sp MODEL DATA - FOR COMPRES			-
1	Manu	facturer:	Gardner Denver			
	Model	l Number:	STG2-125HP-200psi	Date:	7/21/2020	
2		Air-cooled	X Water-cooled	Туре:	Screw	
				# of Stages:	1	
3	* Rated C	Capacity at Full Load Operating Pressure a, e		472.0	acfm ^{a,e}	
4		ad Operating Press		200	psig ^b	
5		um Full Flow Oper		200	psig ^c	
6	Drive N	Iotor Nominal Rat		125	hp	
7 Drive Motor Nominal Efficiency			iciency	95.4	percent	
	Ean Ma	otor Nominal Ratin	g (if applicable)	NA	hp	
	Ean Ma	otor Nominal Effici	iency	NA	percent	
10		ackage Input Powe	er at Zero Flow ^e	22.4	kW ^e	
1	Total Pa	ackage Input Powe	er at Rated Capacity and Full Load	110.80	kW^d	
12	Package	Operating Pressure ^d Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e			kW/100 cfm ^e	
1	3 Isentrop	ic Efficiency		81.56	Percent	
Cons	sult CAGI webs TES: a b c d	site for a list of partic . Measured at the disch ISO 1217, Annex C; / . The operating pressur for this data sheet. . Maximum pressure att maximum pressure att . Total package input p	Performance Verification Program, these items are vipants in the third party verification program: arge terminal point of the compressor package in accord ACFM is actual cubic feet per minute at inlet conditions. e at which the Capacity (Item 3) and Electrical Consumptainable at full flow, usually the unload pressure setting is ainable before capacity control begins. May require add ower at other than reported operating points will vary w in ISO 1217, Annex C, as shown in table below:	www.cagi.org lance with ption (Item 11) were measure for load/no load control or the ditional power.	d	
Compressed Air & Gas Ir		1	ower" and "energy" are synonymous for purposes of this	document.		
			Volume Flow Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member		<u>m³ / min</u>	<u>ft³ / min</u>	%	%	%
		Below 0.5	Below 17.6	+/- 7	+/- 8	
		0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
DOT 020 1		1.5 to 15	53 to 529.7 Above 529.7	+/- 5	+/- 6	
ROT 030.1		Above 15	AUUVE 329.1	+/- 4	+/- 5	

ROT 030.1

12/19 Rev 2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.