COMPRESSOR DATA SHEET



In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Displacement

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer: (Sardner Denver							
	Model Number: S	AVG2-125-150psi		Date:	07/21/20				
2	Air-cooled	X Water-cooled		Type:	Screw				
	X Lubricated Oil Free			# of Stages:	1				
3*	Full Load Operating Pr	ing Pressure b		psig b					
4	Drive Motor Nominal Rating		125	hp					
5	Drive Motor Nominal Efficiency		95.4	percent					
6	Fan Motor Nominal Ra	ting (if applicable)	NA	hp					
7	Fan Motor Nominal Ef	ficiency	NA	percent					
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	110.8		528	20.98					
8*	94.4		423	22.32					
	83.8		344	24.39					
	75.4		266	28.37					
	74.2		215	34.50					
9*		Гоtal Package Input Power at Zero Flow ^{с, d}		kW					
10	Isentropic Efficiency a Capacity and Full Load		78.8	%					
11	35.00 - 30.00 -								
	Specific Power (KV)100 A CEN) 10.00 10.00	50 100 150 200	250 300 350 400	450 500 5:	50 600 650				
		0 50 100 150 200 250 300 350 400 450 500 550 600 650 Capacity (ACFM)							
	Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity								

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 032.1

5/20. Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data