

## **COMPRESSOR DATA SHEET**

## Federal Uniform Test Method for Certain Air Compressors Not Applicable **Rotary Compressor: Fixed Speed**

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner I	Denver					
2		r-cooled Type:	3/3/2021 Screw				
	Oil Injected X Oil-F	ree # of Stages:	2				
3*	Rated Capacity at Full Load Operating	Pressure a, e 390.0	acfm <sup>a, e</sup>				
4	Full Load Operating Pressure b	150	psig b				
5	Maximum Full Flow Operating Pressu	re <sup>c</sup> 153	psig				
6	Drive Motor Nominal Rating	100	hp				
7	Drive Motor Nominal Efficiency	95.1	percent				
8	Fan Motor Nominal Rating (if applical	ble) 5.0	hp				
9	Fan Motor Nominal Efficiency	89.5	percent				
10*	Total Package Input Power at Zero Flo	e 21.0	kW <sup>e</sup>				
11	Total Package Input Power at Rated C Load Operating Pressure <sup>d</sup>	apacity and Full 93.3	kW <sup>d</sup>				
12*	Specific Package Input Power at Rated Full Load Operating Pressure	Capacity and 23.92	kW/100 cfm <sup>e</sup>				

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
  The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured
- for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power		
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%		
Below 0.5	Below 17.6	+/- 7	+/- 8			
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%		
1.5 to 15	53 to 529.7	+/- 5	+/- 6	T/- 10/0		
Above 15	Above 529.7	+/- 4	+/- 5			



Member

ROT 030.2

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: