## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MO	DEL DAT	A - FOR	COMPRE	ESSED AIR			
1	Manufacturer:	Gard	ner Denver						
	Model Number: VST110-74hp(2S)-125ps				si Date:			01/04/2	
2	X Air-cooled Water-cooled			ed		T	ype:	Screw	
						# of Sta		2	
3*	Full Load Operating Pressure b				125		b psig		
4	Drive Motor Nominal Rating				2 x 74		hp		
5	Drive Motor Nominal Efficiency				94.0		percent		
6	Fan Motor Nominal Rating (if applicable)			le)	10		hp		
7	Fan Motor Nominal Efficiency				89.5		percent		
8*	Input Power (kW)			(	Capacity (acf	m) <sup>a,d</sup>	Specific Power (kW/100 acfm)		
	129.80				751.0		17.28		
	116.68				675.9		17.26		
	104.35				600.8		17.37		
	92.66				525.7		17.63		
	81.37				450.6		18.06		
	57.10			o d	289.0		19.76		
9*	Total Package Input Power at Zero Flow c, d			w c, d	0.0		kW		
10	Isentropic Efficiency				83.51			%	
	Power (CFM)	35.00							
11	Specific Power (kW/100 ACFM)	20.00						-	
		10.00	100.0 20	00.0 300.	0 400.0	500.0 600.	0 700.0	800.0	
	Capacity (ACFM)  Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity								

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

1	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B