## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
	Model Number: VST75-50hp(2S)-125psi		Date:	01/04/21			
2	Air-cooled X Water-cooled		Type:	Screw			
		# (	of Stages:	2			
3*	Full Load Operating Pressure b	125		psig b			
4	Drive Motor Nominal Rating	2 x 50	hp				
5	Drive Motor Nominal Efficiency	94.0	percent				
6	Fan Motor Nominal Rating (if applicable)	NA	hp				
7	Fan Motor Nominal Efficiency	NA	percent Specific Power				
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	90.51	513.0	17.64				
8*	76.65	436.1	17.58				
0	63.75	359.1	17.75				
	52.05	282.2	18.45				
	40.92	205.2	19.94				
	27.30 c, G	119.0	22.94				
9*	Total Package Input Power at Zero Flow	0.0	kW				
10	Isentropic Efficiency	pic Efficiency 82.42		%			
11	35.00 30.00 25.00 25.00 15.00						
	0.0 100.0	200.0 300.0 400.0	500.0	600.0			
	Capacity (ACFM)  Note: Graph is only a visual representation of the data in Section 8						
	Note: Y-Axis Scale, 10 to	35, + 5kW/100acfm increments if necessary cale, 0 to 25% over maximum capacity					

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST55-90B