## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

## **Rotary Compressor: Variable Displacement**

			enver						
	Model Number: SAV-300hp-EAU-100psi   Air-cooled X   Water-cooled						Date:		01/04/2
2							Type:		Screw
	X Lubrica	h	Free	-	100	# of	Stages:		1 . b
}*	Full Load Opera	Load Operating Pressure					psig		
4	Drive Motor Nominal Rating				300		hp		
5	Drive Motor Nominal Efficiency				95.8		percen		
6	Fan Motor Nominal Rating (if applicable)				N/A		hp		
7	Fan Motor Nominal Efficiency				N/A		per Specific Powe		
	Input Power (kW)			Capa	acity (acf	m) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	268.8				1481		18.15		
8*	249.0				1333		18.68		
	214.2				1037		20.66		
	185.2				741		24.99		
	176.7				592		29.85		
)*	Total Package Input Power at Zero Flow c, d				48.4		kW		
0	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0 200	600	800	1000	1200	1400	1600	
		200	400	Capacity (					

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



Member

ROT 032.2

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

		olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
	$\underline{m}^3 / \underline{min}$	$\underline{\mathrm{ft}}^3$ / min	%	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8		
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
1 *	Above 15	Above 529.7	+/- 4	+/- 5		

6/20 Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: EAU99AA