COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Fixed Speed MODEL DATA - FOR COMPRESSED AIR Manufacturer: 1 **Gardner Denver** 1/4/2021 Model Number: L05-7.5hp-110psi-3PH Date: 2 \mathbf{X} Air-cooled Water-cooled Type: **Screw** Oil-injected Oil-free # of Stages: 1 Rated Capacity at Full Load Operating Pressure a, e acfm^{a,e} 3* 28.2 Full Load Operating Pressure b 4 110 psig Maximum Full Flow Operating Pressure c psig^c 5 117 **Drive Motor Nominal Rating** 7.5 6 hp **Drive Motor Nominal Efficiency** 7 89.5 percent Fan Motor Nominal Rating (if applicable) 8 N/A hp Fan Motor Nominal Efficiency 9 N/A percent Total Package Input Power at Zero Flow^e kW^{e} 10* 2.5

NOTES:

11

12*

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

Total Package Input Power at Rated Capacity and

Specific Package Input Power at Rated Capacity

Full Load Operating Pressure^d

and Full Load Operating Pressure

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

NOTE. The terms power and energy are synonymous for purposes of this document.					
	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	m ³ /min	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
	Above 15	Above 529.7	+/- 4	+/- 5	

6.90

24.47

 kW^{d}

 $kW/100 cfm^e$

Member

ROT 030.2

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: L04-05A

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org