COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner D	enver					
	Model Number: L110RS(F)		Date:	12/17/21			
2	X Air-cooled Water-cooled			Type:	Screw		
				# of Stages:	1		
3*	Full Load Operating Pressure b	Load Operating Pressure b			psig b		
4	Drive Motor Nominal Rating	Motor Nominal Rating			hp		
5	Drive Motor Nominal Efficiency	7	95.8		percent		
6	Fan Motor Nominal Rating (if a	Motor Nominal Rating (if applicable)			hp		
7	Fan Motor Nominal Efficiency	Motor Nominal Efficiency			percent		
8*	Input Power (kW)		Capacity (acfm)	an	Specific Power (kW/100 acfm) ^d		
	138.25		714.2		19.36		
	118.04		612.1		19.29		
8"	97.98		507.4		19.31		
	78.02		398.9		19.56		
	59.05		286.5		20.61		
	42.47	- 1	179.0		23.72		
9*	Total Package Input Power at Ze	ero Flow c, d	76.52		kW		
10	Isentropic Efficiency	tropic Efficiency			%		
11	35.00 30.00 30.00 25.00 20.00 10.00 10.00		500.0 600.0	700.0 800.0			
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity						

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS90-132