rev A

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable **Rotary Compressor: Fixed Speed**

2	Model Number T74			
2		Date:	3/3/2021	
	Air-cooled X Water-cooled	Type:	Screw	
	Oil Injected X Oil-Free	# of Stages:	2	
3* R	ated Capacity at Full Load Operating Pressure a, e	424.0	acfm ^{a, e}	
4 Fi	ull Load Operating Pressure b	100	psig ^b	
5 M	Maximum Full Flow Operating Pressure ^c	103 psig ^c		
6 D	Drive Motor Nominal Rating	100	hp	
7 D	Drive Motor Nominal Efficiency	95.1	percent	
8 Fa	an Motor Nominal Rating (if applicable)	0.5	hp	
9 Fa	an Motor Nominal Efficiency	80.5	percent	
10* T	otal Package Input Power at Zero Flow ^e	17.3	kW ^e	
11	otal Package Input Power at Rated Capacity and Full oad Operating Pressure ^d	79.7	kW ^d	
12*	pecific Package Input Power at Rated Capacity and ull Load Operating Pressure ^e	18.80	kW/100 cfm ^e	

b. The operating pressure at which the Capacity (item 3) and Electrical Consumption (item 11) were measured for this data sheet.
c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
d. Total package input power at other than reported operating points will vary with control strategy.

- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Above 529.7

Above 15



Member

Gardner

Denver

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m^3} / \underline{min}$	<u>ft³ / min</u>	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%

+/- 4

+/- 5

ROT 030.2

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data