## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

	T	OR COMPRESSED	AIR		
1	Manufacturer: Gardner Denver				
	Model Number: ENV TVS315 -125psi-460V		Date:	05/11/21	
2	Air-cooled X Water-cooled		Type:	Screw	
	Lubricated X Oil Free		# of Stages:	2	
3*	Full Load Operating Pressure b	125	h		
4	Drive Motor Nominal Rating	<b>422</b> hp			
5	Drive Motor Nominal Efficiency	96.2 percent			
6	Fan Motor Nominal Rating (if applicable)	2	hp		
7	Fan Motor Nominal Efficiency	86.5	percent		
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	352.10	1716.3	20.52		
8*	298.40	1507.9	19.79		
0,	251.50	1285.5	19.57		
	209.60	1052.4	19	19.92	
	171.30	822.8	20.82		
	135.40	603.9	22.42		
9*	Total Package Input Power at Zero Flow	27.4 kW		kW	
10	Note: Graph is only a vi	800.0 1000.0 1200.0  Capacity (ACFM)  isual representation of the data in So. + 5kW/100acfm increments if necessions.		1800.0 2000.0	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: ENVTVS200-315A