COMPRESSOR DATA SHEET



In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Displacement

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Gardner Denver						
	Model Number:	SAVG2-150HP-175psi		Date:	09/15/20			
2	X Air-cooled Water-cooled			Type:	Screw			
	X Lubricated Oil Free			# of Stages:	1			
3*	Full Load Operating Pressure b		175	psig b				
4	Drive Motor Nominal Rating		150	hp				
5	Drive Motor Nominal Efficiency		95.8	percent				
6	Fan Motor Nominal Rating (if applicable)		5	hp				
7	Fan Motor Nom	Fan Motor Nominal Efficiency		percent				
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	123.6		525	23.54				
	107.6	i	422	25.50				
	96.6		343	28.20				
	87.1		262	33.	27			
	86.2		210	41.07				
9*		nput Power at Zero Flow c, d	27.4	kW				
10		iency at Full Flow Rated all Load Operating Pressure	76.0		%			
11	45.00 40.00 35.00 20.00 10.00 50 100 150 200 250 300 350 400 450 500 550 600 650 Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity							

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 032.1

/20. Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.