## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

## **Rotary Compressor: Variable Displacement**

1	Manufacturer:	Gardn	er Denver					
2	Model Number: SAV-400hp-EAY-100psi   X Air-cooled Water-cooled			i	Date:	01/04/21		
					Type:	Screw		
	X Lubricated Oil Free			1	# of Stages:	1 . b		
3*	Full Load Operat	Full Load Operating Pressure <sup>b</sup>				psig		
4	Drive Motor Nominal Rating			400		hp		
5	Drive Motor Nominal Efficiency			95.8		percent		
6	Fan Motor Nominal Rating (if applicable)			20		hp		
7	Fan Motor Nominal Efficiency			89.5		percent Specific Power		
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	-	<u>7/100 acfm)<sup>d</sup></u>		
	367.1			1943	18.			
8*	341.4			1749	19.	.52		
	295.9			1360	21.	.76		
	258.1			972	26.	.55		
	246.9			777	31.	.78		
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>			78.9		kW		
10	35.00 30.00 30.00 25.00 25.00 20.00 15.00 10.00							
		0	500	1000 1500	2000	2500		
		Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity						

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



Member

ROT 032.2

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

		olume Flow Rate pecified conditions	Volume Flow Rate Specific Energy Consumption		Zero Flow Power	
	$\underline{m}^3 / \underline{min}$	$\underline{\mathrm{ft}}^3$ / min	%	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8		
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
1 *	Above 15	Above 529.7	+/- 4	+/- 5		

6/20 Rev2 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: EAY99J