## **COMPRESSOR DATA SHEET**



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

		MOD	EL DATA - FO	OR COMPRESSI	ED AIR		
1	Manufacturer:	Gardne	er Denver				
	Model Number: VST150-100hp(2S)-125p  X Air-cooled Water-cooled			psi Date:		01/04/2	
2					Type:	Screw	
					# of Stages:	2	
3*	Full Load Operating Pressure b			125		psig b	
4	Drive Motor No.	Drive Motor Nominal Rating				hp	
5	Drive Motor No.	Drive Motor Nominal Efficiency				percent	
6	Fan Motor Nom	Fan Motor Nominal Rating (if applicable)		10		hp	
7	Fan Motor Nom	n Motor Nominal Efficiency				percent Specific Power	
8*	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>		(kW/100 acfm) <sup>d</sup>	
	175.70			986.0		17.82	
	145.93			838.1		17.41	
8.	119.03			690.2		17.25	
	95.16			542.3		17.55	
	73.06			394.4		18.52	
	57.00		c, d	289.0		19.72	
9*	Total Package Input Power at Zero Flow			0.0		kW	
10	Isentropic Efficiency			84.89		%	
11		35.00					
	30.00						
	Specific Power (kW/100 ACFM)	25.00					
	Specifi (kW/10	20.00	0.00				
		15.00					
		10.00					
		0.0	200.0 40		800.0 100	00.0 1200.0	
			Note: Granh is only a v	Capacity (ACFM) isual representation of the data	in Section 8		
		Not	e: Y-Axis Scale, 10 to 35,	+ 5kW/100acfm increments if ne 0 to 25% over maximum capacit	cessary above 35		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: VST110-180B