## COMPRESSOR DATA SHEET

Gardner Denver

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Fixed Speed** MODEL DATA - FOR COMPRESSED AIR Manufacturer: **Gardner Denver** 1 Model Number: STG2-250hp-125psi Date: 3/1/2022 2 X Water-cooled Air-cooled Type: Screw # of Stages: 1 Rated Capacity at Full Load Operating Pressure a, e acfm<sup>a,e</sup> 3\* 1242.2 psig Full Load Operating Pressure 4\* 125 Maximum Full Flow Operating Pressure c psig 5 128 **Drive Motor Nominal Rating** 6 250 hp Drive Motor Nominal Efficiency 7 96.2 percent Fan Motor Nominal Rating (if applicable) 8 N/A hp Fan Motor Nominal Efficiency 9 N/A percent Total Package Input Power at Zero Flow<sup>e</sup> 67.9  $kW^{e}$ 10\* Total Package Input Power at Rated Capacity and Full Load 224.41  $kW^{d}$ 11 Operating Pressure<sup>d</sup> Package Specific Power at Rated Capacity and Full Load Operating 12\* 18.07 kW/100 cfm<sup>e</sup> Pressure 83.15 13 Isentropic Efficiency Percent

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
- maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

Member

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: ST250-300G2A

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.