

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable **Rotary Compressor: Fixed Speed**

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
2				3/3/2021 Screw			
	Oil Injected X Oil-Free		# of Stages:	2			
3*	Rated Capacity at Full Load Operating Pressu	re ^{a, e}	424.0	acfm ^{a, e}			
4	Full Load Operating Pressure b	ating Pressure b		psig b			
5	Maximum Full Flow Operating Pressure c		103	psig ^c			
6	Drive Motor Nominal Rating		100	hp			
7	Drive Motor Nominal Efficiency		95.1	percent			
8	Fan Motor Nominal Rating (if applicable)		5.0	hp			
9	Fan Motor Nominal Efficiency		89.5	percent			
10*	Total Package Input Power at Zero Flow ^e		21.4	kW ^e			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure		85.6	kW ^d			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure 20.20		20.20	kW/100 cfm ^e			

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
 The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured
- for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

1 0, 1, 1, 1						
Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power		
m ³ / min	ft ³ / min	%	%	%		
Below 0.5	Below 17.6	+/- 7	+/- 8			
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%		
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 1070		
Above 15	Above 529.7	+/- 4	+/- 5			

Member

ROT 030.2

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: