47728683001 rev A



COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Gardner Denver						
	Model Number TVS37		Date:	03/03/21			
2	Air-cooled X Water-cooled		Type:	Screw			
	Lubricated X Oil-Free		# of Stages:	2			
3*	Full Load Operating Pressure ^b	100	psig ^b				
4	Drive Motor Nominal Rating	50	hp				
5	Drive Motor Nominal Efficiency	94.7	percent				
6	Fan Motor Nominal Rating (if applicable)	0.5	hp				
7	Fan Motor Nominal Efficiency	70.0	percent				
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d				
	45.2	200	22.62				
	40.7	179	22.79				
8*	36.0	157	22.90				
	31.5	136	23.24				
	27.3	114	23.95				
	23.1	93	24.93				
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0		kW			
	35.00						
	Specific Power (KW1100 ACFN) 20.00						
10	20.00 - 15.00						
	10.00 0 25 50 75	100 125 150 175	200 225	250 275			
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity						

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m³/min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data