Gardner Denver

COMPRESSOR	DATA	SHEET
------------	------	-------

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	MOD	EL DATA - FO	R COMPRESSED	AIR		
1	Manufacturer: Gardne	r Denver				
	Model Number TVS45			Date:	03/03/21	
2	Air-cooled X W	ater-cooled		Type: Screw		
	Lubricated X Oi		# of Stages:	2		
3*	Full Load Operating Pressur	re ^b	125	psig ^b		
4	Drive Motor Nominal Ratin	Drive Motor Nominal Rating		hp		
5	Drive Motor Nominal Effici	Drive Motor Nominal Efficiency			percent	
6	Fan Motor Nominal Rating (if applicable)		0.5	hp		
7	Fan Motor Nominal Efficier	псу	70.0		percent	
	Input Power (kW)		Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d		
	54.6		219	24.94		
	49.6		198	25	.06	
8*	44.8		176	25.39		
	40.1		155	25.88		
	35.5		134	26.52		
	30.5		112	27	.15	
9*	Total Package Input Power	at Zero Flow ^{c, d}	0.0		kW	
10	30.00 30.00 30.00 25.00 15.00 10.00 0 25 Not	C Note: Graph is only a visu e: Y-Axis Scale, 10 to 35, +	100 125 150 17 apacity (ACFM) tal representation of the data in 5 5kW/100acfm increments if neces	Section 8	250 275	
	s that are tested in the CAGI Performa GI website for a list of participants in a. Measured at the discharge ter ACFM is actual cubic feet pe b. The operating pressure at wh c. No Load Power. In accordan manufacturer may state "not	nce Verification Prog the third party verific minal point of the com r minute at inlet conditi ich the Capacity (Item 4 ce with ISO 1217, Ann significant" or "0" on th	ation program: pressor package in accordan ons. 3) and Electrical Consumptic ex E, if measurement of no I ne test report.	www.cagi.org ce with ISO 1217, Ar on (Item 8) were mea	nnex E; asured for this data she	
er	 d. Tolerance is specified in ISO NOTE: The terms "power" a 			ocument.		
	Volume Flow Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power		

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	m ³ /min	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
ROT 031.2	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.