COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1	Manufacturer: G	ardner Denver				
	Model Number: L	200RS-272hp-190psi		Date:	01/04/21	
2	X Air-cooled Water-cooled			Type:	Screw	
				# of Stages:	1	
3*	Full Load Operating P	ressure	190		psig	
4	Drive Motor Nominal	ve Motor Nominal Rating			hp	
5	Drive Motor Nominal	rive Motor Nominal Efficiency			percent	
6	Fan Motor Nominal Ra	ating (if applicable)	3.0 / 7.4	/ .4 hj		
7	Fan Motor Nominal Ef	ficiency	86.7 / 89.6		percent	
	Input Power (kW)		Capacity (acfm) ^{a,c}		Specific Power (kW/100 acfm) ^d	
	252.50		1027.3		24.58	
	211.59		858.7		24.64	
8*	173.40		691.9	2	25.06	
	137.77		526.9	2	26.15	
	104.55		363.5	2	28.76	
	73.51		201.0	3	36.57	
9*	Total Package Input P	ower at Zero Flow ^{c, d}	17.9		kW	
10	Isentropic Efficiency				%	
	40.00					
	35.00 -					
	30.00 25.00 25.00 25.00		<			
11	20.00 -					
	15.00 -					
	10.00 +	200.0 400	0.0 600.0	800.0 1000.	0 1200.0	

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

ROT 031.1

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	$\underline{\mathrm{ft}^3} / \mathrm{min}$	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7		
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: LRS160-290C